

GUJARAT TECHNOLOGICAL UNIVERSITY**M.E Sem-II Examination July 2010****Subject code: 721107****Subject Name: Energy Conservation and Management****Date: 09 / 07 / 2010****Time: 11.00am – 1.30pm****Instructions:****Total Marks: 60**

1. Attempt all questions.
2. Make suitable assumptions wherever necessary.
3. Figures to the right indicate full marks.
4. Use of student's own tables and chart is allowed.

- Q.1** (a) Define energy management and state principles of energy management. **06**
 (b) Explain flywheel effect of building materials and explain the terms pull down load, ICL and IHG. **06**

- Q.2** (a) Explain the term energy audit and detailed energy audit methodology. **06**
 (b) Explain: Bench marking, pay back period, PEP. **06**

OR

- (b) Explain energy management strategies for industry and explain any one. **06**

- Q.3** The following data is available for a room. Calculate the instantaneous cooling load through a roof at 4 PM. The following data be used : **12**
 Outside design condition : 43°C DBT, 27°C WBT
 Inside design condition : 26°C DBT, 50% RH
 $U_{\text{roof}} = 2.7 \text{ W/m}^2 \text{ K}$, Mass of the roof : 390.6 kg/m²
 Correction in TETD = 6.4°C
 Time lag = 5 hrs.
 Roof area = 20m X 20m
 Roof position: Sunlit and shaded, for 40°N latitude, July 21.

OR

- Q.3** (a) Enlist the different loads on residential building and Explain how to calculate the cooling load for residential buildings **06**
 (b) Give detail classification of energy and explain Indian energy scenario with respect to coal and oil supply. **06**

- Q.4** (a) List out the energy efficient electrical devices and explain any one of them. **06**
 (b) Give tips on how to save fuel in automobile vehicle? **06**

OR

- Q.4** (a) Explain electricity end uses in industry. **06**
 (b) Explain the factors considered for electrical billing. **06**

- Q.5 (a)** The following data is available for a gasturbine based co-generation power plant: capacity of gas turbine generator : 4000kW
 Plant operating hours per annum : 8000
 Plant load factor : 90%
 Heat rate as per standard given by the gas turbine supplier : 3049.77 kcal/kWh.
 Waste heat boiler parameters (unfired steam output) : 10 TPH
 Steam temperature & pressure : 200°C and 8.5 kg/m²
 steam enthalpy : 676.44 kcal/kg
 fuel used : Natural gas
 LCV : 950 kcal/m³
 Price of gas : Rs.3000/1000m³
 Capital investment for total Co-generation plant : Rs. 1300 Lakhs.
 Estimate the cost of power and steam generation.
- (b)** What are the advantages of waste heat recovery? Write a short note on heat pipe with neat sketch. Also state application of it
- Q.5 (a)** Classify the co-generation systems and explain bottoming cycle **06**
(b) Write a short note on heat recovery and waste heat boilers **06**
